



## CONSTRUCTION PRODUCTS REGULATION 2011 DECLARATION OF PERFORMANCE

**DoP No: LAI.DC.021**

1. Unique identification code of the product-type:

**Orbis 31 807.30 Overhead Slide Arm Door Closer (Pull side door mounted application only)**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**Orbis 31 807.30 Slide Arm Door Closer (Pull side door mounted application only)**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**For use on fire and smoke compartmentation doors when fitted in accordance with the manufacturer's fitting instructions**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**LIDLAW LIMITED  
STRAWBERRY LANE, WILLENHALL,  
WEST MIDLANDS WV13 3RS,  
UNITED KINGDOM**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**N/A**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

**System 1**

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**EN 1154: 1996: A1: 2002  
Notified Certification body No.1121 issued the EC certificate**

8. European Technical Assessment:

**N/A**

9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
<u>Self closing</u> 5.2.1 General  Application  5.2.2 Durability 5.2.3 Closing moment 5.2.4 Opening moment 5.2.5 Efficiency  5.2.6 Closing time 5.2.7 Angles of operation 5.2.8 Overload performance 5.2.9 Temperature dependence 5.2.10 Fluid leakage 5.2.11 Damage 5.1.12 Latch control 5.1.13 Backcheck 5.1.14 Delayed Action 5.1.15 Adjustable closing force 5.1.16 Zero position (double action only) 5.1.18 Fire / smoke doors	Door Mount Pull Side (Fig 1)  500,000 Pass size 3 Pass size 3 >55%  Pass Grade 3, 110° Pass -15°C to +40°C Pass Pass Pass Pass Pass N/A N/A N/A  Pass see other documents for details	EN 1154: 1996: A1: 2002
Essential characteristics	Performance	Harmonised technical specification
<u>Durability of Self Closing</u> 5.2.2 Durability 5.2.17.1 corrosion 5.2.17.2 corrosion  <u>Dangerous Substances</u> <u>Annex ZA3</u>	500,000 Grade 3 (96 hours) Pass  The materials in the products(s) do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	EN 1154: 1996: A1: 2002

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

**Signed for and on behalf of the manufacturer by:**

Mr Steve Lee  
 Chief Executive Officer  
 Date of issue: 01/03/2018  
 Strawberry Lane  
 Wolverhampton, West Midlands WV13 3RS  
 United Kingdom

